

Drinking Water Quality and Compliance

Northern Settlement of Sled Lake – 2022 Annual Notice to Consumers

Introduction

The Water Security Agency and the Ministry of Environment requires that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister's Order or Permit to Operate a waterworks. The following is a summary of the Northern Settlement of Sled Lake water quality and sample submission compliance record for the January 1, 2022 to December 31, 2022 time period. This report was completed on June 19, 2023. Readers should refer to Water Security Agency's Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502 for more information on minimum sample submission requirements and the meaning of type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of Selenium in a water supply", more detailed information is available from: http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html.

Water Quality Standards

Bacteriological Quality

Positive Regular Parameter/Location	Limit	Regular Samples		# of
		Required	Submitted	
Total Coliform	0 Organisms/100 mL	24	26	0%
E. coli	0 Organisms/100 mL	24	26	0%

Water Disinfection –

Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit Chlorine (%)	Total Chlorine Residual Range	Free Chlorine Residual Range	# Tests	# Tests Required	# Adequate Submitted
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	0.42 to 1.11	0.26 to 1.15	24	26	80.77%

Water Disinfection - Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.16	0.24 to 1.44	365	0

A minimum of 0.16 milligrams per litre (mg/L) free chlorine residual is required for water entering the distribution system. Tests are normally performed on a daily basis by the waterworks operator and are to be recorded in operation records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values) and the number of tests and percentage of results not meeting the minimum requirement of 0.16 mg/L free chlorine residual.

Turbidity – From Water Treatment Plant Records

Parameter	Limit (NTU)	Test Level Range	# Tests Not Meeting Requirements	Maximum Turbidity (NTU)	# Tests	# Tests
Turbidity	1.0	0.21 to 0.75	0	0.75	24	26

Chemical – Health Category

All waterworks serving less than 5000 persons are required to submit water samples for WSA's Chemical Health category once every 2 years. The Chemical Health category includes analysis for arsenic, barium, boron, cadmium, chromium, fluoride, lead, nitrate, selenium, and uranium.

A Chemical Health sample was submitted July 7, 2021 and the test results were within the provincial parameters requirements. A Chemical Health sample will be submitted in 2023 as per permit requirements.

General Chemical

All waterworks serving less than 5000 persons are required to submit water samples for WSA's General Chemical category once every two years if a ground water source and once per three months every second year if a surface water or blended surface/groundwater source. The General Chemical category includes analysis for alkalinity, bicarbonate, calcium, carbonate, chloride, conductivity, hardness (as CaCO₃), magnesium, sodium, sulphate and total dissolved solids.

A General Chemical sample was submitted on August 18, 2021 and the sample was within the provincial guideline parameters. A General Chemical sample will be submitted in 2023 as per permit requirements.

More information on water quality and sample submission performance may be obtained from:

Northern Municipal Trust Account
Northern Settlement of Sled Lake
c/o NMS Advisor
Box 113, La Ronge, SK S0J 1L0
Tel: 1-800-663-1555
Fax: 1-306-425-2401
E-mail address: nms@gov.sk.ca

June 2015 EPB 536D



**Saskatchewan
Ministry of
Environment**

