

March 13, 2026

Via Email:

sandra.galambos@gov.sk.ca
districtpwm@outlook.com

Attention Waterworks Owner/Operator:

RE: Precautionary Drinking Water Advisory for the Northern Settlement of Missinipe - Rescinded

The Water Security Agency is advising that the “Precautionary Drinking Water Advisory” (PDWA) issued by the Water Security Agency for the Northern Settlement of Missinipe’s water distribution system has been rescinded, effective immediately.

The rescinding of the PDWA was based upon information provided by your operational staff, which included:

- The receipt of two consecutive sets of two (four total) bacteriological samples collected 24 hours apart from the water distribution system are negative for bacteriological growth.

You may return to normal water quality monitoring requirements as detailed in your Permit to Operate a Waterworks. Thank you for your cooperation during this event. For further information, please contact the undersigned at 306.960.6290 or Neil.Hodges@wsask.ca.

Sincerely,



Neil Hodges
Environment Officer
Water Security Agency

cc: Greg Holovach, Water Security Agency (email)
Water Advisories, Water Security Agency
Saskatchewan Health Authority, La Ronge