



**Northern Settlement of Wollaston**  
**Drinking Water Quality and Compliance**  
**Annual Notice to Consumers**  
**2024**

**Introduction**

The Water Security Agency and the Ministry of Environment require that at least once each year waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the waterworks in submitting samples as required by a Minister’s Order or Permit to Operate a waterworks. The following is a summary of the **Northern Settlement of Wollaston** water quality and sample submission compliance record from January 1, 2024, to December 31, 2024. This report was completed on June 18, 2025. Readers should refer to the Water Security Agency’s “Municipal Drinking Water Quality Monitoring Guidelines, June 2015, EPB 502” for more information on minimum sample submission requirements. Permit requirements for specific waterworks may require more sampling than outlined in the department’s monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, “What is the significance of selenium in a water supply”, more detailed information is available from:

[http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index\\_e.html](http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html) .

**Water Quality Standards**

**Bacteriological Quality**

<b>Parameter/Location</b>	<b>Limit</b>	<b>Regular Samples Required</b>	<b>Regular Samples Submitted</b>	<b># of Positive Regular Submitted (%)</b>
Total Coliform	0 Organisms/100 mg/L	24	15	0%
E. coli	0 Organisms/100 ml	24	15	0%
Background Bacteria	Less than 200 Organisms/100 mL	24	15	0%

The owner/operator submits 100 percent of all bacteriological samples as required. All waterworks are required to submit samples for bacteriological water quality, the frequency of monitoring depends on the population served by the waterworks.

**Water Disinfection**

**Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples**

<b>Parameter</b>	<b>Minimum Limit (mg/L)</b>	<b>Free Chlorine Residual Range</b>	<b>Total Chlorine Residual Range</b>	<b># Tests Required</b>	<b># Tests Submitted</b>	<b># Adequate Chlorine (%)</b>
Chlorine Residual	0.1 mg/L free OR 0.5 mg/L total	0.05- 0.46	0.16- 0.6	24	15	100%

Unless otherwise approved, a minimum of 0.1 milligrams per liter (mg/L) free chlorine residual OR 0.5 mg/L total chlorine residual is always required throughout the distribution system. A proper chlorine submission is defined as a bacteriological sample submission form filled out with both the free and total chlorine residual fields. Adequate chlorine is a result that indicates that the chlorine level is above the regulated minimum. Adequate chlorine may be counted even if the chlorine results were submitted incorrectly. A waterworks is required to submit chlorine residual test results on every bacteriological sample they submit.



**Water Disinfection**

**Free Chlorine Residual for Water Entering Distribution System from Waterworks Records-From Water Treatment Plant Records**

Parameter	Limit (mg/L)	Test Level Range	# Tests Performed	# Tests Not Meeting Requirements
Free Chlorine Residual	at least 0.1	0.04 – 0.87	366	8

A minimum of 0.1 milligrams per liter (mg/L) of free chlorine residual is required for water entering the distribution system. Tests are normally performed daily by the waterworks operator and are to be recorded in operational records. This data includes the number of free chlorine residual tests performed, the overall range of free chlorine residual (highest and lowest recorded values), and the number of tests and percentage of results not meeting the minimum requirement of 0.1 mg/L free chlorine residual.

**Chemical – Trihalomethanes (THMs) and Halo acetic Acids (HAAs)**

Parameter	Limit IMAC (mg/L)	Sample Result (average)	# Samples Required	# Samples Submitted
Trihalomethanes (THMs)	0.1	.05347	4	3
Halo acetic Acids (HAAs)	0.080	.05	4	3

THMs and Halo acetic Acids are generated during the water disinfection process as a by-product of reactions between chlorine and organic material. THMs are generally found only in drinking water obtained from surface water supplies. THMs and HAAs are to be monitored quarterly and the IMAC result is expressed as an average of 4 quarterly samples. Only water supplies derived from surface water or groundwater under the influence of surface water are required to monitor THMs and Halo acetic Acids unless otherwise specified in the facility's Permit to Operate.

**More information on water quality and sample submission performance may be obtained from:**

Northern Municipal Trust Account  
Northern Settlement of Wollaston  
c/o District Public Works Manager  
Box 113 La Ronge, SK. S0J 1L0  
E-mail address: nms@gov.sk.ca